



# Certificate of Compliance

**Certificate:** 1692818

**Master Contract:** 154088

**Project:** 2563103

**Date Issued:** October 24, 2012

**Issued to:** Dynisco

3829 Forest Pkwy, Suite 500  
Wheatfield, NY 14120-3707  
USA  
Attention: Bruce R. Temple

*The products listed below are eligible to bear the CSA Mark shown*



*Joe da Silva*

**Issued by:** Joe da Silva, C.E.T.

## **PRODUCTS**

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 1, Groups B, C, and D; Class II, Div. 1, Groups E, F and G; Class III, Div. 1; Encl. Type 4X:

· Pressure Transducer, Series SPX 22XX and SPX 53XX, rated 16 - 40Vdc input, 4 - 20mA analog output; Max. Ambient Temperature 85°C; Temperature Code T5 Ta = 85°C, T6 Ta = 60°C; Working Pressure Range 75 psi to 60,000 psi.

## **APPLICABLE REQUIREMENTS**

CAN/CSA C22.2 No. 0-M91 - General Requirements-Canadian Electrical Code, Part II

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

## **MARKINGS**

- CSA Monogram



**Certificate:** 1692818

**Master Contract:** 154088

**Project:** 2563103

**Date Issued:** October 24, 2012

---

- Company Name
- Model number
- Serial number
- Electrical ratings
- Enclosure Type 4X (if applicable)
- Hazardous Location designation
- Temperature Code T6 (85°C)/T5 (100°C)
- Max. Ambient Temperature 85°C/60°C
- Caution re. "Use Supply Wires Suitable for 20°C above Surrounding Ambient"
- The warning: "Warning In Hazardous Areas Do Not Remove Screws when Circuit is Live"
- The words "Seal Not Required"

Note: Jurisdictions in Canada may require these markings to be also in French. It is the responsibility of the Customer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities.